

## Waste Water Treatment Plant Düren, Germany



fig.: decanter plant

system: decanter Z6E OSE

thickening of surplus sludge

capacity: 60-90 m<sup>3</sup>/h

dry solid content inlet: 0,5 – 0,6 %

dry solid content discharge: 6 %

system: Dekanter Z6E HTS

dewatering of mixed sludge

capacity: 50 m<sup>3</sup>/h

dry solid content inlet: 1,8 – 6,5 %

dry solid content discharge: 30 - 35 %